

		PFAS Compounds (parts per trillion)					
		PFOA	PFOS	PFHxS	PFNA	HFPO-DA	PFBS
		Final MCL (effective 2029)	4.0	4.0	10	10	NA
		State Action Levels	10	15	65	9	345
10/30/2024	Well 1 & 2 Treatment	ND	4.99	ND	ND	ND	2.09
	Well 3	ND	2.62	ND	ND	ND	ND
	Well 4**	NS	NS	NS	NS	NS	NS
	Well 5	ND	2.41	ND	ND	ND	ND
1/31/2025	Well 1 & 2 Treatment	Down for Maintenance - No Sample Taken					
	Well 3	ND	2.78	ND	ND	ND	2.12
	Well 4**	NS	NS	NS	NS	NS	NS
	Well 5	ND	2.82	ND	ND	ND	ND
5/8/2025	Well 1 & 2 Treatment	ND	4.86	ND	ND	ND	4.54
	Well 3	ND	2.57	ND	ND	ND	2.14
	Well 4**	NS	NS	NS	NS	NS	NS
	Well 5	ND	2.51	ND	ND	ND	2.17
8/14/2025	Well 1 & 2 Treatment	ND	5.08	ND	ND	ND	4.53
	Well 3	ND	2.27	ND	ND	ND	2.32
	Well 4**	NS	NS	NS	NS	NS	NS
	Well 5	ND	3.47	ND	ND	ND	2.99
10/9/2025	Well 1 & 2 Treatment	ND	4.92	ND	ND	ND	5.06
	Well 3	ND	2.51	ND	ND	ND	2.4
	Well 4**	NS	NS	NS	NS	NS	NS
	Well 5	ND	2.8	ND	ND	ND	2.98
Scheduled 1/2026	Well 1 & 2 Treatment						
	Well 3						
	Well 4**	NS	NS	NS	NS	NS	NS
	Well 5						

ND = not detected; NS = not sampled

Results that are listed in **bold font** are detection levels that exceed the future MCL for the associated compound.

* The Hazard Index (HI) is a long-established approach that EPA regularly uses to understand health mixture (i.e., exposure to multiple chemicals). The HI is made up of a sum of fractions. Each fraction is the ratio of each PFAS measured in the water to the health-based water concentration.

[For more information on how the HI is calculated visit this link.](#)

**Well 4 is inactive and has not yet been sampled for Initial Monitoring

Hazard Index (Unitless)
Mixtures containing two or more of PFHxS, PFNA, HFPO DA, and PFBS
1
NA
0*
0*
NS
0*
n
0*
NS
0*
0*
0*
NS
0*
0*
NS
0*
0*
NS
0*
NS

ted compound.

th risk from a chemical
on compares the level of