



## Legislation Details (With Text)

**File #:** AM No. 19-153  
**Type:** Consent Item  
**Status:** Passed  
**File created:**  
**In control:** City Council  
**On agenda:** 10/15/2019  
**Final action:** 10/15/2019  
**Title:** Approval of Supplemental Agreement No. 1 to the Consultant Agreement with Gray & Osborne for Engineering and Construction Support Services in the Amount of \$726,452, for the SE Redmond Tank Painting and Seismic Upgrade, Project No. 20021801

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. Agenda Memo No. 19-153, 2. Attachment A: Vicinity Map, 3. Attachment B: Supplemental Agreement No. 1

Date	Ver.	Action By	Action	Result
10/15/2019	1	City Council	approved	Pass

**MEMO TO:** Members of the City Council

**FROM:** Mayor John Marchione

**SUBJECT:**

Approval of Supplemental Agreement No. 1 to the Consultant Agreement with Gray & Osborne for Engineering and Construction Support Services in the Amount of \$726,452, for the SE Redmond Tank Painting and Seismic Upgrade, Project No. 20021801

### **I. RECOMMENDED ACTION**

Recommend Council approve Supplemental Agreement No. 1 to the Consultant Agreement with Gray & Osborne for Engineering and Construction Support Services in the Amount of \$726,452, for the SE Redmond Tank Painting & Seismic Upgrade, Project No. 20021801

### **II. DEPARTMENT CONTACTS**

Dave Juarez, Public Works Director	425-556-2733
Gary Schimek, Environmental and Utility Services, Division Manager	425-556-2742
Lynn Arakaki, Senior Engineer, Environmental and Utility Services	425-556-2841
Joseph O'Leary, Senior Project Manager, Construction Division	425-556-2738

### **III. DESCRIPTION/BACKGROUND**

The City owns and operates a four and one-half million-gallon (4.5 MG) water storage tank in SE Redmond. The tank is located at 18609 NE 65th St., across the street from Fire Station 16 and Genie Industries. The steel tank was constructed in 1996 and is scheduled for exterior and interior paint recoating.

The contract consultant, Gray & Osborne Inc., has completed their preliminary evaluation of the existing tank coatings as well as the seismic structural design from 1996. The evaluation report recommends that the tank re-coatings move forward, and the seismic design be updated to a higher structural performance level. This project will also make other improvements to the tank, installing new safety railings, storm gutters, support piping and telemetry system updates.

The water tank will need to be taken off-line and drained during construction to recoat the interior surfaces and to upgrade the seismic system. The temporary shutdown will occur outside of the summer peak period. The shutdown will have no impact to water service because of the built-in redundancy of the City water system. Education Hill and Perrigo water tanks are capable of providing continuous water supply while the SE Redmond Tank is under construction.

#### **IV. PREVIOUS DISCUSSIONS HELD**

<b>Date</b>	<b>Action / Committee Presentation</b>
04/16/2019	Committee of the Whole meeting
05/07/2019	City Council meeting - Consent
10/08/2019	Committee of the Whole meeting
Today	City Council meeting - Consent Supplement 1

#### **V. IMPACT**

##### **A. Service/Delivery:**

When the SE Redmond Tank painting and seismic upgrade is completed, the water storage tank will have an extended life cycle and will continue to deliver water utility service to business and residences for many more years. Further, the steel tank will have an increased structural strength in withstanding damage from an earthquake.

##### **B. Fiscal Note:**

Project was fully funded with Council approval of 2019-2020 budget.

Design Phase	\$ 611,383
Construction Phase	<u>\$ 5,276,315</u>
Total Estimated Project Cost	\$ 5,887,698
Project Funding	\$5,887,698

#### **VI. ALTERNATIVES TO STAFF RECOMMENDATION**

The Council may reject the proposed consultant agreement for the painting and seismic upgrade for SE Redmond Tank. Delaying the painting protective coating and seismic upgrade could reduce the operational performance of the water tank.

## **VII. TIME CONSTRAINTS**

The water tank diameter is over 100 feet, the height is over 60 feet. The exterior and interior tank paint surfaces will have to be sand blasted and painted. The tank interior and exterior area covers a larger area than two football fields. The seismic work will also be time consuming. The outer steel tank ring will likely have to be reinforced. Construction for the project may take up to ten months.

## **VIII. LIST OF ATTACHMENTS**

Attachment A: Vicinity Map

Attachment B: Supplemental Agreement No. 1